شركة بشاير البناء للمقاولات
Bashaer Al-Benaa Contracting Company

شركة الشرق للاستشارات الهندسية
e c e c

الهيئة السعودية للسياحة
SAUDI TOURISM AUTHORITY

Prototype:		Site:	FITOUT PROJECT AL-RAED RIYADH	Submittal No.	087	Rev.# Of Copies	1
Title:	Masonary Sound isolation resalts		MAT - site - Disc	Serial	BBC-ECE-AR-TEC-01-R01		
To:	CONSULTANT		Date:	31/12/2022			

TECHNEICAL SUBMITTAL

Attachments:	Sample		Catalogue / Manuals		Compliance Cert.		Manufacturer Data & Specs	✓	
Drawings	Procedures		Spare Parts List		Calculation Sheet		Others/Specify		
Submitted for:	Approval			Information			As Requested,		

Material Description	CONTRACTOR NAME	Reference Specs #
Test Results of STC as Specifications Requirments from EL.MIDEFER Company	EL.MIDEFER COMPANY	

To be used for: GROUP: 1 2 3

For Contractor:

PROJECT Manager:	Engr/ Tarek Reafat	Signature		Date	31/12/2022
Doc. Control Mgr.	Ahmed Yousuf	Signature		Date	31/12/2022

We certify that the above items have been reviewed in detail, they are correct and in strict conformance with the contract drawings and specifications except as otherwise stated, and the material source indicated above has been reviewed in detail and shall supply the submitted items in full conformity with timely delivery.

Engineer's Representative to enter Action Codes, Remarks, and return to Contractor.

Remarks: * INFORMATION PROVIDE SHOULD BE COMPLY MINUTES OF MEETING #10 S.N/ITEM 1-5th Flow block work ACCOUSTIC SOUND PROOF BLOCK SHOULD BE 53 db.
* FINAL APPROVAL SHALL BE GIVEN AS PER SPEC & CLIENT INSTRUCTION.

Corrections or comments made relative to submittals during this review do not relieve the contractor from full compliance with the requirements of the contract's documents, dimensions selecting fabrication processes and techniques of construction; coordinating his work with that of other trades, and performing his work in a safe and satisfactory manner and correlating all quantities and conformance with the design concept of the project and general compliance with the information given in the contract documents. The contractor is responsible for the provided specifications. This check is only for general review

Action:							
	A	APPROVED AS SUBMITTED		B	APPROVED AS NOTED	✓	C REVISE AND RESUBMIT
	D	REJECTED		E	FOR INFORMATION ONLY		

	For Engineer's Representative		For STA Representative
Review By:	NAME: AMIR KHAN	SIGNATURE:	DATE: 31/12/2022

Consultans:

Name: .....
Signature: .....
Dtae: 01/01/2023

Client Representative:

Name: .....
Signature: .....
Dtae: 1-1-23

1/1/23

Received

1